

**IMPORTANT**

1. Always include complete heater model and serial number so that any specification change can be considered for parts shipment. It can save time and expense.
2. Specifications are subject to change without notice.
3. We reserve the right to substitute functional replacements
4. Order by Part Number. Do not order by Option Number.

Replacement Parts

Applies to: **Model F** and **Model FE**
Fan-Type, Gas-fired
Unit Heaters and
Model B and **Model BE**
Blower-Type, Gas-fired
Unit Heaters


**Model F, Fan-Type,
 Gravity Vent**

**Model B, Blower-Type,
 Gravity Vent**

***Model FE, Fan-Type,
 Power Vent**

***Model BE, Blower-
 Type, Power Vent**


*Models FE and BE are
 no longer manufactured.

Index


A	Hinge Pin Assy 16	Relay 4, 6, 14, 15
Air Shutter 12	I	Replacement Parts Tag 2
B	Ignition Controllers 5	Restrictor 8
Belt 10, 11	Ignition Conversion Kits 5	S
Belt Guard 19	K	Sensing Tube 14
Blocked Vent Switch 4	Key 8	Serial Number 2, 3
Blower 8	L	Starter 9
Blower Components 8	Latch Fastener 16	Starters 10
Blower/Filter Cabinet 19	Limit Control 4	Summer/Winter Switch 4
Blower Guard 19	Vertical Louver Assy 18	Swivel Connection 18
Burner Only 12	Low Ambient Fan Control 6	T
Burner Orifices 13	M	Terminal Strip 4
Burner Rack 12	Manifold 12	Thermocouple 13
Burner Rack Support 12	Model No. 2	Thermostat Bracket 5
Burner Rack Supports 16	Belt-Driven Motor 8	Thermostats 5
C	Blower Motor 9	Stepdown Transformer 6
Cabinet Parts 16	Blower Motors 10	Transformers 5
Capacitor 8, 14, 15	Direct Drive Motor 8	V
Carryover 12	Fan Motor 7	Shut-off Valve 12
Circuit Breaker 4	Venter Motor 14	Vent Cap 14, 15, 18
Contactor 9, 10	Motor Adjustment Mounting Assy 8	Vent Damper 5
D	Motor Band 8	Venter 14
Date of Manufacture 3	Motor Mounting Bracket 8	Venter Fan Blade 14
Dates of Introduction 3	Motor Support 8	Venter for Gravity-Vent Units 15
Downturn Nozzle Kit 20	Multiple Heater Control 6	Venter Gasket 14
Drive 10	N	Venter Motor and Wheel Assembly 14
Duct Flange 18	Nozzles 20	Venter Wheel 14
E	O	W
Electrical Components 4	Burner Orifices 12	Warranty 3
F	Overload 9, 10	
Fan Blades 7	P	
Fan Components 7	Paint 18	
Fan Control 4	Match-Lit Pilot 13	
Fan Guard 7	Spark Pilot 13	
Fan Motor Spacing 7	Pilot Shield 12	
Filters 19	Polytube Adapters 20	
Flame Sensor 13	Pressure Switch 14, 15	
Fuse 4	Blower Pulley 10, 11	
G	Motor Pulley 10, 11	
Gasket Kit 16	R	
Guards 19	Rating Plate 2	
H	References 3	
Hanger Kits 18		
Heat Exchangers 16		

Electrical Components

Code	Description		Size									
			25	50	75/100	125	130/165	200	250	300	400	
1	ECO Limit Control*	F/FE	131449 Thermodisc #G4AP0202110C, 109°C (replaces 96513)		82414, Thermodisc #G4AP0200152C, 152°C							
*Not on any units after 2008. F&B with match-lit pilot have an ECO limit control. FE&BE and F&B with optional spark pilot manufactured prior to 8/99 have an ECO limit control.		B/BE			131450, Thermodisc #G5AP0201152C, 152°C (replaces 82414 on blower heaters)							
2	Limit Control - heaters mfgd beginning 9/96 (Serial No. Date Code AVI)	FE	85449, 200°F			82091, 160°F	85449, 200°F	45602, 180°F				
		F	85449, 200°F		45602, 180°F	82091, 160°F	85449, 200°F	45602, 180°F				
		BE	45602, 180°F			100799, 150°F						
		B	45602, 180°F	85449, 200°F		100799, 150°F						
	Limit Control - heaters mfgd prior to 9/96	FE	85449, 200°F			82091, 160°F	85449, 200°F	45602, 180°F				
		F	85449, 200°F		45602, 180°F	82091, 160°F	85449, 200°F	45602, 180°F				
		BE	45602, 180°F			100799, 150°F						
		B	45602, 180°F			100799, 150°F						
3	Fan Control, Thermodisc #60T12 with Bracket (See NOTE below.)	F/FE	123974, 105/135°F (replaces 96387)		123976, 95/135°F (replaces 114009)			123974, 105/135°F (replaces 96387)				
		B/BE	123975, 95/150°F (replaces 100857)									
4	Summer/Winter Switch Assembly (Same as Option CH1)	F/FE	98484 (Includes switch and wiring)									98485
		B/BE	101679 (Includes switch, relay, and wiring)									
5	2-Screw Terminal Strip		96041 - for 24V connections									
6	4-Screw Terminal Strip		96511 - for 24V connections									
7	RBM Relay	-	P/N18549 (included in 2-stage control options)									
8	Time Delay Relay		--	--	97479, Thermodisc #305048							

NOTE: Temperature settings on the current replacement fan controls are different from the previous models because of a change in construction of the switch. However, these controls are interchangeable and will perform a nearly identical control function.

Code 1 - ECO Device



Code 2 - Limit Control, Automatic Reset



Code 3 - Fan Control Assembly



Code 4 - Summer/Winter Switch



Code 5 - Two-Screw Terminal Strip Connector, P/N 96041



Code 6 - Four-Screw Terminal Strip Connector, P/N 96511



Code 7 - RBM Relay, P/N 18549



Code 8 - Time Relay Delay, P/N 97479



Code	Description		Size					
			25	50	75/100	125	130/165/200	250/300/400
9A	Blocked Vent Switch , Thermdisc #36Tx46, 1/2" Snap Disk, manual reset, 1/4" QC (standard on gravity-vent models beginning April 1991 - Applies to Standard single units only (See Code 9B, Gasket)		112751 - Setting Open @ 200°F #6215	112752 - Setting Open @ 225°F #6217	121275 - Setting Open @ 275°F #6279			
	Blocked Vent Switch , Thermdisc #36Tx46, 1/2" Snap Disk, manual reset, 1/4" QC (standard on gravity-vent models beginning April 1991 - Applies to optional two-stage units only (See Code 9B, Gasket)		--	--	112752 - Setting Open @ 225°F #6217			
9B	Blocked Vent Gasket - for heaters with single-stage controls		--	(2) 121341	--	--	--	--
	Blocked Vent Gasket - for heaters with optional two-stage controls		--	--	(1) 121341	--	(1) 121341	--
10	Circuit Breaker W58XB1A4A8	(Fusible disconnect	146831					
11	On/Off Switch, McGill 4125-0004	Option A11)	146830					

Code 9A - Blocked Vent Switch



Code 10 - Circuit Breaker, P/N 146831



Code 11 - On/Off Switch, P/N 146830



Code 12 - Fuse and Fuse Holder for Blower Units with Optional 575 Volt

Fuse, 2.5 amp, 2501, #3120, **P/N 60242**
 Fuse Holder, Buss HTB-481, **P/N 60241**

