

Modulating Gas Controls

CODE	Description	In Gas Cntrl Option	Serial No. Suffix	Location	P/N
60	Temperature Sensor, Maxitrol Series 14, #TS114	AG30, AG31	MV-7	Discharge	90324
	Temperature Sensor, Maxitrol Series 14A, #TS114A	AG32	MV-8	Discharge	87106
	Temperature Sensor, Maxitrol Series 14B, #TS114B	AG35	MV-8	Discharge	123944
	Temperature Sensor, Maxitrol Series 44, #TS44E, 120°F max	AG33	MV-9	Discharge	119617
	Temperature Sensor, Maxitrol Series 44, #TS44C, 140°F max				194160
	Temperature Sensor, Maxitrol Series 94, #TS194A	AG36	MV-B	Discharge	133228
	Temperature Sensor, Maxitrol Series 14E, #TS394-2B-4	AG47, AG48,	MV-D, MV-E,	Outside & Return Air	204452
	Temperature Sensor, Maxitrol Series 14E, #TS194Q	AG51	MV-F	Discharge	204453
61	Mixing Tube, Maxitrol MTI-12	All above		Same as above	90323
62	Amplifier, Maxitrol Series 14 & 14A, #A1014L	AG 30, 31, 32	MV-7, MV-8	Electrical Control Compartment (See page 2.)	148590
	Amplifier, Maxitrol Series 44, #A1044EL, 120°F maximum	AG33	MV-9		157915
	Amplifier, Maxitrol Series 44, #A1044CL, 140°F maximum				194159
	Amplifier, Maxitrol Series 94, A1494	AG36	MV-B		133229
	Amplifier, Maxitrol Series 14E, ADFM14	AG47	MV-D		204454
	Amplifier, Maxitrol Series 44E-21 & 44ER-21, ADFM44	AG48, AG51	MV-E, MV-F		204450
63	Signal Conditioner, Maxitrol	AG37	MV-C		134170
64	Temperature Selector, Maxitrol Series 14, #TD114	AG30, AG31	MV-7	Remote	86988 (USA); 101165 (Canada)
	Temperature Selector, Maxitrol Series 14A, #TD114A	AG32	MV-8	Remote	87107
	Temperature Selector, Maxitrol Series 14B, #TD114B	AG35	MV-8	Remote	159285
	Temperature Selector, Maxitrol Series 14E, #TDDFM14	AG47	MV-D	Remote	204455
	Selectrastat (temperature selector), Maxitrol Series 44, #T-244	AG33	MV-9	Space	86990
	Temperature Selector, Maxitrol Series 44E, #TDDFM44	AG48, AG51	MV-E, MV-F	Remote	204451
	Temperature Selector, Maxitrol Series 94, #TD294E-609-0818	AG36	MV-B	Remote	133230, 120°F; 159287, 160°F
65	Overriding Thermostat, Series 14, #T115	AG 30, 31, 32	MV-7, MV-8	Space	24857

CODE 60 - Temperature Sensor



P/N 90324, Maxitrol #TS114;
P/N 87106, Maxitrol #TS114A
(illustrated);
P/N 123944, Maxitrol #TS114B

P/N 119617, Maxitrol #TS44E;
P/N 194160, Maxitrol #TS44C;
P/N 133228, Maxitrol TS194A



P/N 204452, Maxitrol #TS394-2B-4;
P/N 204453, Maxitrol #TS194Q (illustrated)

IMPORTANT NOTE: When replacing a temperature sensor on a Maxitrol MV-9 system (Option AG33), check the Model No. on the sensor. P/N 119617 or 194160 is used on units manufactured beginning 2/92; P/N 87041 is used on units manufactured prior to 2/92. **Sensors are not interchangeable; the sensor MUST match the amplifier.**

CODE 62 - Amplifier (Amplifiers are not interchangeable and must match the temperature sensor.)

P/N 148590,
Maxitrol #A1014L
(replaces P/N 86976)



P/N 204454,
Maxitrol #ADFM14



CODE 61 - Mixing Tube, P/N 90323



P/N 194159, Maxitrol #A1044CL;
P/N 157915, Maxitrol #A1044EL
(replaces P/N 119616);
P/N 86989, Maxitrol #A1044 (on systems mfgd prior to 2/91)



P/N 133229,
Maxitrol #A1494



P/N 204450, Maxitrol #ADFM44



CODE 63 - Maxitrol Signal Conditioner, P/N 134170 (for computer control)



CODE 64 - Temperature Selectors (see chart for option application)



P/N 86988, TD114 U.S. Models, Range 55-90°F
P/N 101165, TD114, Canadian Models, Range 50-75°F;
P/N 87107, TD114A, Range 80-130°F;
P/N 159285, TD114B, Range 120-160°F;

P/N 204455,
TD DFM14;
P/N 204451,
TD DFM44



P/N 86990,
Selectrastat
Maxitrol T-244



P/N 133230, Maxitrol #TD294E-609-0818, Dual Temperature Selector for Paint Booth Application, Option AG36



CODE 65 - P/N 24857, Maxitrol #T115, Overriding Thermostat, Option AG33

