

IMPORTANT

1. Always include complete heater model and serial number so that any specification change can be considered for parts shipment. It can save time and expense.
2. Specifications are subject to change without notice.
3. We reserve the right to substitute functional replacements
4. Order by Part Number not by Option Number.

Replacement Parts

Applies to: **Model F and Model FE**
Fan-Type, Gas-Fired
Unit Heaters and
Model B and Model BE
Blower-Type, Gas-Fired
Unit Heaters

**Model F, Fan-Type,
Gravity Vent**



**Model B, Blower-Type,
Gravity Vent**



***Model FE, Fan-Type,
Power Vent**



***Model BE, Blower-
Type, Power Vent**



*Models FE and BE are no longer manufactured.

Index

A

Air Shutter 12

B

Belt 10, 11
 Belt Guard 19
 Blocked Vent Switch 4
 Blower 8
 Blower Components 8
 Blower/Filter Cabinet 19
 Blower Guard 19
 Burner Only 12
 Burner Orifices 13
 Burner Rack 12
 Burner Rack Support 12
 Burner Rack Supports 16

C

Cabinet Parts 16
 Capacitor 8, 14, 15
 Carryover 12
 Circuit Breaker 4
 Contactor 9, 10

D

Date of Manufacture 3
 Dates of Introduction 3
 Downturn Nozzle Kit 20
 Drive 10
 Duct Flange 18

E

Electrical Components 4

F

Fan Blades 7
 Fan Components 7
 Fan Control 4
 Fan Guard 7
 Fan Motor Spacing 7
 Filters 19
 Flame Sensor 13
 Fuse 4

G

Gasket Kit 16
 Guards 19

H

Hanger Kits 18
 Heat Exchangers 16
 Hinge Pin Assembly 16

I

Ignition Controllers 5
 Ignition Conversion Kits 5

K

Key 8

L

Latch Fastener 16
 Limit Control 4
 Vertical Louver Assembly 18
 Low Ambient Fan Control 6

M

Manifold 12
 Model No. 2
 Belt-Driven Motor 8
 Blower Motor 9
 Blower Motors 10
 Direct Drive Motor 8
 Fan Motor 7
 Venter Motor 14
 Motor Adjustment Mounting Assembly 8
 Motor Band 8
 Motor Mounting Bracket 8
 Motor Support 8
 Multiple Heater Control 6

N

Nozzles 20

O

Burner Orifices 12
 Overload 9, 10

P

Paint 18
 Match-Lit Pilot 13
 Spark Pilot 13
 Pilot Shield 12

Polytube Adapters 20
 Pressure Switch 14, 15
 Blower Pulley 10, 11
 Motor Pulley 10, 11

R

Rating Plate 2
 References 3
 Relay 4, 6, 14, 15
 Replacement Parts Tag 2
 Restrictor 8

S

Sensing Tube 14
 Serial Number 2, 3
 Starter 9
 Starters 10
 Swivel Connection 18

T

Terminal Strip 4
 Thermocouple 13
 Thermostat Bracket 5
 Thermostats 5
 Stepdown Transformer 6
 Transformers 5

V

Shut-off Valve 12
 Vent Cap 14, 15, 18
 Vent Damper 5
 Venter 14
 Venter Fan Blade 14
 Venter for Gravity-Vent Units 15
 Venter Gasket 14
 Venter Motor and Wheel Assembly 14
 Venter Wheel 14

W

Warranty 3

Electrical Components

Code	Description		Size								
			25	50	75/100	125	130/165	200	250	300	400
1	ECO Limit Control (not on any units mfgd <i>after</i> 2008, F&B with match-lit pilot have ECO limit control, FE&BE and F&B with optional spark pilot mfgd <i>before</i> AUG 1999 have ECO limit control)	F/FE	131449 Thermodisc #G4AP0202110C, 109°C (replaces 96513)		82414, Thermodisc #G4AP0200152C, 152°C						
		131450, Thermodisc #G5AP0201152C, 152°C (replaces 82414 on blower heaters)									
2	Limit Control (heaters mfgd <i>after</i> AUG 1996, Serial No. Date Code AVI)	FE	85449, 200°F				82091, 160°F	85449, 200°F	45602, 180°F		
		F	85449, 200°F			45602, 180°F	82091, 160°F	85449, 200°F	45602, 180°F		
		BE	45602, 180°F				100799, 150°F				
		B	45602, 180°F	85449, 200°F		100799, 150°F					
	Limit Control (heaters mfgd <i>before</i> SEP 1996)	FE	85449, 200°F				82091, 160°F	85449, 200°F	45602, 180°F		
		F	257531, 200°F			45602, 180°F	82091, 160°F	85449, 200°F	45602, 180°F		
		BE	45602, 180°F				100799, 150°F				
		B	45602, 180°F				100799, 150°F				
3	Fan Control, Thermodisc #60T12 with Bracket (see NOTE below)	F/FE	123974, 105/135°F (replaces 96387)		123976, 95/135°F (replaces 114009)			123974, 105/135°F (replaces 96387)			
		B/BE	123975, 95/150°F (replaces 100857)								
4			Obsolete (12/16)								
5	2-Screw Terminal Strip		96041 (for 24V connections)								
6	4-Screw Terminal Strip		96511 (for 24V connections)								
7	RBM Relay	Units mfgd <i>after</i> AUG 2011, PN 18549 (included in 2-stage control options)									
		For units mfgd <i>before</i> SEP 2011 (Serial No. Date Code BKI), order Replacement Kit PN 263527 (relay is standard in BE & FE and with 2-stage control options)									
8	Time Delay Relay		—		—		97479, Thermodisc #305048				

NOTE: Temperature settings on the current replacement fan controls are different from the previous models because of a change in construction of the switch. However, these controls are interchangeable and will perform a nearly identical control function.

Code 1 - ECO Device 	Code 2 - Limit Control, Automatic Reset 	Code 3 - Fan Control Assembly 
Code 5 - Two-Screw Terminal Strip Connector, PN 96041 	Code 6 - Four-Screw Terminal Strip Connector, PN 96511 	Code 7 - RBM Relay, PN 18549 
		Code 8 - Time Relay Delay, PN 97479 

Code	Description		Size					
			25	50	75/100	125	130/165/200	250/300/400
9A	Blocked Vent Switch, Thermdisc #36T × 46, 1/2" Snap Disk, manual reset, 1/4" QC, standard on gravity-vent models mfgd <i>after</i> MAR 1991, applies to Standard single units only (see Code 9B - Gasket)		112751, Setting Open @ 200°F #6215	112752, Setting Open @ 225°F #6217	121275 (Setting Open @ 275°F #6279)			
	Blocked Vent Switch, Thermdisc #36T × 46, 1/2" Snap Disk, manual reset, 1/4" QC, standard on gravity-vent models <i>after</i> MAR 1991, applies to optional two-stage units only (see Code 9B - Gasket)		—	—	112752 (Setting Open @ 225°F #6217)			
9B	Blocked Vent Gasket, for heaters with single-stage controls		—	(2)121341	—	—	—	—
	Blocked Vent Gasket, for heaters with optional two-stage controls		—	—	(1) 121341	—	(1) 121341	—
10	Circuit Breaker W58XB1A4A8	(Fusible disconnect	146831					
11	On/Off Switch, McGill 4125-0004	Option A1)	146830					

Code 9A - Blocked Vent Switch 	Code 10 - Circuit Breaker, PN 146831 	Code 11 - On/Off Switch, PN 146830 	Code 12 - Fuse and Fuse Holder for Blower Units with Optional 575 Volt Fuse, 2.5 amp, 2501, #3120, PN 60242 Fuse Holder, Buss HTB-481, PN 60241 
---	--	--	---